

Power Supplies

POWER SUPPLY VARIATIONS		
Code	Voltage Mark	Admissible Limits
A	230 VAC	196...252 VAC
B	115 VAC	98...126 VAC
C	90...250 V	80...250 VAC / 105...260 VDC
K	24...230 V	20...230 VAC / 24...250 VDC
P	12...24 V	8...25 VAC / 11...32 VDC
Q	12...24 V, isolated	10...26 VAC / 12...32 VDC
R	24 VAC, isolated	21...26 VAC

Захранващи напрежения

ЗАХРАНВАЩИ НАПРЕЖЕНИЯ		
Код	Означение	Допустими граници
A	230 VAC	196...252 VAC
B	115 VAC	98...126 VAC
C	90...250 V	80...250 VAC / 105...260 VDC
K	24...230 V	20...230 VAC / 24...250 VDC
P	12...24 V	8...25 VAC / 11...32 VDC
Q	12...24 V, изолирано	10...26 VAC / 12...32 VDC
R	24 VAC, изолирано	21...26 VAC